

RZ 1. NP-1/9 (tp=46°C)	PZ 1: Plovoucí podlaha
Systém TACKER	Io/lp=89.4 m/21.4 m
Lpz=150 [mm]	1.10 - host.pokoj
PZ:26°C	Trubka RAUTHERM S 17x2,0
S=13.4 m2	Nast.=2.50 Otv. (2.1 l/min)

RZ 1. NP-1/10 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=54.5 m/16.4 m
Lpz=200 [mm]	1.11 - Pracovna
PZ:28°C	Trubka RAUTHERM S 17x2,0
S=10.9 m2	Nast.=0,25 (1.2 l/min)

RZ 1. NP-1/11 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=32.3 m/10.0 m
Lpz=150 [mm]	1.12 - Koupelna
PZ:31°C	Trubka RAUTHERM S 17x2,0
S=4.8 m2	Nast.=0,25 (0.4 l/min)

RZ 1. NP-1/12 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=37.3 m/4.5 m
Lpz=150 [mm]	1.01 - Zádveří
PZ:27°C	Trubka RAUTHERM S 17x2,0
S=5.6 m2	Nast.=0,25 (0.8 l/min)

<b>- 1.10 -</b>	
host.pokoj	
13.4 m2	33.8 m3
20 °C	1029 W

<b>- 1.13 -</b>	
Chodba	
7.3 m2	18.5 m3
20 °C	185 W

<b>- 1.11 -</b>	
Pracovna	
10.9 m2	27.4 m3
20 °C	555 W

<b>- 1.12 -</b>	
Koupelna	
5.8 m2	14.5 m3
24 °C	347 W

<b>- 1.01 -</b>	
Zádveří	
5.6 m2	14.1 m3
15 °C	280 W

<b>- 1.03 -</b>	
strojovna	
4.2 m2	10.7 m3
20 °C	176 W

<b>- 1.02 -</b>	
vstupní hala	
8.0 m2	20.0 m3
20 °C	201 W

tm=42°C	Plovoucí podlaha
Systém TACKER	lp=66.6 m
L=205 [mm]	1.13 - Chodba
PZ:25°C	--
S=7.3 m2	--

tm=41°C	Plovoucí podlaha
Systém TACKER	lp=69.1 m
L=214 [mm]	1.02 - vstupní hala
PZ:25°C	--
S=8.0 m2	--

<b>- 1.04 -</b>	
Jídlna s kuchyňským koutem	
17.6 m2	44.4 m3
20 °C	1147 W

RZ 1. NP-1/1 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=79.9 m/8.7 m
Lpz/Loz=200/100 [mm]	1.04 - Jídlna s kuchyňským koutem
PZ:28°C	Trubka RAUTHERM S 17x2,0
S=13.6 m2	Nast.=0,25 (1.4 l/min)

RZ 1. NP-1/3 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=89.3 m/14.3 m
Lpz/Loz=200/100 [mm]	1.05 - Obývací pokoj
PZ:28°C	Trubka RAUTHERM S 17x2,0
S=15.7 m2	Nast.=0,38 (1.6 l/min)

<b>- 1.09 -</b>	
Šatna	
6.1 m2	15.4 m3
20 °C	498 W

<b>- 1.08 -</b>	
Ložnice	
16.7 m2	41.9 m3
20 °C	1205 W

<b>- 1.06 -</b>	
Koupelna	
8.8 m2	22.1 m3
24 °C	719 W

<b>- 1.05 -</b>	
Obývací pokoj	
33.3 m2	112.2 m3
20 °C	2339 W

RZ 1. NP-1/8 (tp=46°C)	PZ 1: Plovoucí podlaha
Systém TACKER	Io/lp=40.8 m/36.3 m
Lpz=150 [mm]	1.09 - Šatna
PZ:26°C	Trubka RAUTHERM S 17x2,0
S=6.1 m2	Nast.=0,55 (2.0 l/min)

RZ 1. NP-1/7 (tp=46°C)	PZ 1: Plovoucí podlaha
Systém TACKER	Io/lp=55.9 m/28.6 m
Lpz/Loz=150/100 [mm]	1.08 - Ložnice
PZ:26°C	Trubka RAUTHERM S 17x2,0
S=7.4 m2	Nast.=0,38 (1.8 l/min)

RZ 1. NP-1/6 (tp=46°C)	PZ 1: Plovoucí podlaha
Systém TACKER	Io/lp=58.4 m/18.9 m
Lpz/Loz=150/100 [mm]	1.08 - Ložnice
PZ:26°C	Trubka RAUTHERM S 17x2,0
S=7.8 m2	Nast.=0,32 (1.7 l/min)

RZ 1. NP-1/5 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=57.7 m/18.3 m
Lpz=150 [mm]	1.06 - Koupelna
PZ:31°C	Trubka RAUTHERM S 17x2,0
S=8.7 m2	Nast.=0,25 (1.0 l/min)

RZ 1. NP-1/4 (tp=46°C)	PZ 1: Dlaždice
Systém TACKER	Io/lp=108.0 m/18.8 m
Lpz/Loz=200/100 [mm]	1.05 - Obývací pokoj
PZ:28°C	Trubka RAUTHERM S 17x2,0
S=16.6 m2	Nast.=1.00 (1.8 l/min)

